

CITY OF OAK GROVE, MINNESOTA

2008 BITUMINOUS OVERLAY

CONSTRUCTION PLANS AND SPECIFICATIONS


CLARIFICATION NO. 1

AUGUST 28, 2008

TO ALL BIDDERS: The above titled plans, specifications, and contract documents are hereby revised in accordance with the items set forth herein.

This clarification to the plans and specifications is hereby made a part of the contract documents for the above-entitled project, to the same extent as though it were originally contained therein.

Receipt of this clarification does not need to be acknowledged by entering it on the Bid Form.



Brian D. Miller, P.E.
Project Manager

Please note the following clarification to the plans and specifications for the above-noted project:

SPECIFICATIONS

1. The description as stated on page SP1 in item #1 of the Special Provisions with replace the description as stated in Article 1 -WORK subpart 1.01 of the 'Agreement'.
2. The project schedule as stated on page SP3 in item #11 of the Special Provisions with replace the contract time as stated in Article 4 -CONTRACT TIMES subpart 4.02 of the 'Agreement'. For clarification the Work shall be completed within 46 calendar days instead of 180 calendar days as listed in the 'Agreement'. There will be no phasing for the work on this project.
3. The bituminous mixture for the project shall be a type LV3 wearing course as shown on the bid schedule with a designation of LVWE35030B. The contractor will be allowed to use a recycle bituminous mixture.